

**DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL**

P.O. Box 944246
SACRAMENTO, CA 94244-2460
Website: www.fire.ca.gov
(916) 445-8200



**CALIFORNIA CODE ADOPTION
Meeting Notes
H Occupancy Workgroup
November 15, 2005
Milpitas, CA**

<p><u>ATTENDEES:</u></p> <p>Facilitators: Paul Inouye</p> <p>Committee or Group Members Present: Angela Giuliani, Nadia Naum-Stoian, Ed Sawicki, Ron Keefer, Larry Monette, Jay Swardenski, Steve Rusconi</p> <p>CDF/SFM Staff Present:</p>	<p><u>STAKEHOLDERS IN AUDIENCE:</u></p>
---	--

DOCUMENT HANDOUTS:

1. Ron's summary from Nov 3 meeting
2. Travel distance and panic hardware drafts
3. Height and Area comparison by Mark Kluver

AGENDA:

1. Review nine point criteria drafts
2. Discuss format for submission
3. Update on H8 progress

DISCUSSION/COMMENTS:

Table 105.6.9, add Pyrophoric, permit required for any amount; Table 105.6.21, change corrosive solids to 500 pounds permit amount.

Discussed panic hardware requirements for "H" and exit access travel distance; since "Exiting" is high on SFM priority, agreed to require current CBC requirements if more stringent than IBC.

Egress width, again, require CBC if more stringent.

Table 3104.2.1, change aggregate quantity to 60 gallons, minimum tank size

CONSERVATION IS WISE-KEEP CALIFORNIA GREEN AND GOLDEN

PLEASE REMEMBER TO CONSERVE ENERGY. FOR TIPS AND INFORMATION, VISIT "FLEX YOUR POWER" AT WWW.CA.GOV.

ACTION ITEMS (FOLLOW UP) AND RESPONSIBLES:

1. Need to determine format for final submission (Kent)
2. Final time line (Kent)
- 3.

NEXT MEETING: November 30, 2005; 1330-1630, Menlo Park Fire